



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801
(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: September 25, 2017
Client: JM Sorge, Inc.
KIPP Charter Schools
Address: 57 Fourth Street
Somerville, NJ 08876

Project: KIPP Collegiate Academy

Sample description: Drinking Water / 1st Draw / DWSC3932-1
Sample location: Field Blank
Sampled by: Client
Sample date: 09/15/17
Time: 06:03
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	09/21/17	21:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3932-2
Sample location: Coll-FL1-RKIT-SO1
Sampled by: Client
Sample date: 09/15/17
Time: 06:05
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.43 µg/L	15 µg/L	09/21/17	21:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3932-3
Sample location: Coll-FL1-RKIT-SO2
Sampled by: Client
Sample date: 09/15/17
Time: 06:08
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	27.3 µg/L	15 µg/L	09/21/17	21:55	2	4.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

September 25, 2017
Date



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: September 25, 2017

Client: JM Sorge, Inc.
 KIPP Charter Schools

Address: 57 Fourth Street
 Somerville, NJ 08876

Project: KIPP Life Academy

Sample description: Drinking Water / 1st Draw / DWSC3930-1
 Sample location: Field Blank
 Sampled by: Client
 Sample date: 09/14/17
 Time: 06:40
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	09/21/17	21:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3930-2
 Sample location: Life-FL1-R113-SO1
 Sampled by: Client
 Sample date: 09/14/17
 Time: 06:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	32.0 µg/L	15 µg/L	09/21/17	21:33	2	4.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

September 25th, 2017
 Date



Environmental and Laboratory Services
 90 1/2 West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: September 25, 2017
 Client: JM Sorge, Inc.
 KIPP Charter Schools
 Address: 57 Fourth Street
 Somerville, NJ 08876

Project: KIPP Thrive & Bold Academy

Sample description: Drinking Water / 1st Draw / DWSC3933-1
 Sample location: Field Blank
 Sampled by: Client
 Sample date: 09/14/17
 Time: 06:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	09/21/17	22:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3933-2
 Sample location: TB-FL1-RKIT-KS2
 Sampled by: Client
 Sample date: 09/14/17
 Time: 06:10
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	09/21/17	22:21	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

September 25, 2017
 Date