

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012434631
LIMS Reference ID: AC34631
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: 1600 S 8th Street LIW
Customer PO: 24-1069
EMSL Sales Rep: Justin Monturano
Received: 10/14/2024 10:00
Reported: 10/30/2024 17:33

Analytical Results

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---|--------|---|----|------|-------|--------------------|--------------------|------------------|--------------------------|
| Sample: 1600-WC-Hall1L Lims Reference ID: AC34631-01 Matrix: Drinking Water Sampled: 10/12/24 10:09:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 09:41 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-Hall1R Lims Reference ID: AC34631-02 Matrix: Drinking Water Sampled: 10/12/24 10:11:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 09:43 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-Hall1 Lims Reference ID: AC34631-03 Matrix: Drinking Water Sampled: 10/12/24 10:11:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 09:45 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-SO-KIT Lims Reference ID: AC34631-04 Matrix: Drinking Water Sampled: 10/12/24 10:13:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 09:57 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-IM-KIT Lims Reference ID: AC34631-06 Matrix: Drinking Water Sampled: 10/12/24 10:13:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 09:59 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-Hall2L Lims Reference ID: AC34631-07 Matrix: Drinking Water Sampled: 10/12/24 10:14:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:00 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-Hall2R Lims Reference ID: AC34631-08 Matrix: Drinking Water Sampled: 10/12/24 10:14:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:02 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-Hall2 Lims Reference ID: AC34631-09 Matrix: Drinking Water Sampled: 10/12/24 10:14:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:04 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-02-Hall3L Lims Reference ID: AC34631-10 Matrix: Drinking Water Sampled: 10/12/24 10:15:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:06 | PL | EPA 200.8 (DA)/EPA 200.8 |

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012434631
LIMS Reference ID: AC34631
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: 1600 S 8th Street LIW
Customer PO: 24-1069
EMSL Sales Rep: Justin Monturano
Received: 10/14/2024 10:00
Reported: 10/30/2024 17:33

Analytical Results (Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---|--------|---|----|------|-------|--------------------|--------------------|------------------|--------------------------|
| Sample: 1600-WC-02-Hall3R Lims Reference ID: AC34631-11 Matrix: Drinking Water Sampled: 10/12/24 10:15:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:12 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-02-Hall3 Lims Reference ID: AC34631-12 Matrix: Drinking Water Sampled: 10/12/24 10:18:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:14 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-SO-02-Nurse Lims Reference ID: AC34631-13 Matrix: Drinking Water Sampled: 10/12/24 10:18:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:20 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-02-Nurse Lims Reference ID: AC34631-14 Matrix: Drinking Water Sampled: 10/12/24 10:21:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:22 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-03-Hall4L Lims Reference ID: AC34631-15 Matrix: Drinking Water Sampled: 10/12/24 10:21:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:24 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-03-Hall4R Lims Reference ID: AC34631-16 Matrix: Drinking Water Sampled: 10/12/24 10:24:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:26 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-03-Hall4 Lims Reference ID: AC34631-17 Matrix: Drinking Water Sampled: 10/12/24 10:24:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:28 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-03-FAC Lims Reference ID: AC34631-18 Matrix: Drinking Water Sampled: 10/12/24 10:25:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:30 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-Hall5L Lims Reference ID: AC34631-19 Matrix: Drinking Water Sampled: 10/12/24 10:25:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:29 | 10/29/24 10:32 | PL | EPA 200.8 (DA)/EPA 200.8 |

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012434631
LIMS Reference ID: AC34631
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: 1600 S 8th Street LIW
Customer PO: 24-1069
EMSL Sales Rep: Justin Monturano
Received: 10/14/2024 10:00
Reported: 10/30/2024 17:33

Analytical Results (Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|---|--------|---|----|------|-------|--------------------|--------------------|------------------|--------------------------|
| Sample: 1600-WC-Hall5R Lims Reference ID: AC34631-20 Matrix: Drinking Water Sampled: 10/12/24 10:27:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 02:45 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-Hall5 Lims Reference ID: AC34631-21 Matrix: Drinking Water Sampled: 10/12/24 10:27:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 02:51 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-02-Hall6L Lims Reference ID: AC34631-22 Matrix: Drinking Water Sampled: 10/12/24 10:29:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 02:53 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-02-Hall6R Lims Reference ID: AC34631-23 Matrix: Drinking Water Sampled: 10/12/24 10:29:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 02:55 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-02-Hall6 Lims Reference ID: AC34631-24 Matrix: Drinking Water Sampled: 10/12/24 10:30:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 02:57 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-03-Hall7L Lims Reference ID: AC34631-25 Matrix: Drinking Water Sampled: 10/12/24 10:33:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:03 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-03-Hall7R Lims Reference ID: AC34631-26 Matrix: Drinking Water Sampled: 10/12/24 10:33:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:05 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-03-Hall7 Lims Reference ID: AC34631-27 Matrix: Drinking Water Sampled: 10/12/24 10:33:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:07 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-WC-02-Hall8L Lims Reference ID: AC34631-28 Matrix: Drinking Water Sampled: 10/12/24 10:35:00 | | | | | | | | | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:09 | PL | EPA 200.8 (DA)/EPA 200.8 |

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012434631
LIMS Reference ID: AC34631
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: 1600 S 8th Street LIW
Customer PO: 24-1069
EMSL Sales Rep: Justin Monturano
Received: 10/14/2024 10:00
Reported: 10/30/2024 17:33

Analytical Results (Continued)

| Analyte | Result | Q | DF | RL | Units | Prepared Date/Time | Analyzed Date/Time | Analyst Initials | Prep /Analytical Method |
|----------------------------------|--------|---|--------------------------------------|------|-------|-------------------------------|--------------------|-----------------------------------|--------------------------|
| Sample: 1600-WC-02-Hall8R | | | Lims Reference ID: AC34631-29 | | | Matrix: Drinking Water | | Sampled: 10/12/24 10:35:00 | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:11 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-BF-02-Hall8 | | | Lims Reference ID: AC34631-30 | | | Matrix: Drinking Water | | Sampled: 10/12/24 10:35:00 | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:13 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-SO-03-FAC | | | Lims Reference ID: AC34631-31 | | | Matrix: Drinking Water | | Sampled: 10/12/24 10:37:00 | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:19 | PL | EPA 200.8 (DA)/EPA 200.8 |
| Sample: 1600-FB | | | Lims Reference ID: AC34631-33 | | | Matrix: Drinking Water | | Sampled: 10/12/24 10:38:00 | |
| Metals | | | | | | | | | |
| Lead | ND | | 1 | 1.00 | µg/L | 10/28/24 13:37 | 10/29/24 03:21 | PL | EPA 200.8 (DA)/EPA 200.8 |

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012434631
LIMS Reference ID: AC34631
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: 1600 S 8th Street LIW
Customer PO: 24-1069
EMSL Sales Rep: Justin Monturano
Received: 10/14/2024 10:00
Reported: 10/30/2024 17:33

Certified Analyses included in this Report

| Analyte | Certifications |
|------------------------------------|----------------|
| EPA 200.8 in Drinking Water | |
| Lead | NJDEP |

List of Certifications

| Code | Description | Number | Expires |
|-----------------|--|----------|------------|
| PADEP | Pennsylvania Department of Environmental Protection | 68-00367 | 11/30/2024 |
| NYSDOH | New York State Department of Health | 10872 | 04/01/2025 |
| NJDEP | New Jersey Department of Environmental Protection | 03036 | 06/30/2025 |
| MADEP | Massachusetts Department of Environmental Protection | M-NJ337 | 06/30/2025 |
| CTDPH | Connecticut Department of Public Health | PH-0270 | 06/23/2026 |
| California ELAP | California Water Boards | 1877 | 06/30/2025 |
| AIHA LAP | EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited | 100194 | 01/01/2025 |
| A2LA | A2LA Environmental Certificate | 2845.01 | 07/31/2026 |

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012434631
LIMS Reference ID: AC34631
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: 1600 S 8th Street LIW

Customer PO: 24-1069
EMSL Sales Rep: Justin Monturano
Received: 10/14/2024 10:00
Reported: 10/30/2024 17:33

Notes and Definitions

| Item | Definition |
|-------------|---|
| (Dig) | For metals analysis, sample was digested. |
| [2C] | Reported from the second channel in dual column analysis. |
| DF | Dilution Factor |
| MDL | Method Detection Limit. |
| ND | Analyte was NOT DETECTED at or above the detection limit. |
| NR | Spike/Surrogate showed no recovery. |
| Q | Qualifier |
| RL | Reporting Limit |
| Wet | Sample is not dry weight corrected. |

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS DIVISION
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS DIVISION

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
AC59631

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

| Client Sample ID | Failure to complete will hinder processing of samples | | Collect Date/Time | Matrix W=Water S=Soil A=Air SL=Sludge O=Other | Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other | EPA 200. 8 | List Test(s) Needed | | | | Comments | |
|-------------------------------|---|-------------------------------------|-------------------|--|--|------------------|---------------------|--------------------|------------------|----------------------|----------|--|
| | Comp | Grab | | | | | Field pH | Field pH Test Time | Field Temp Deg C | Field Temp Test Time | | |
| 1600-1M-1011 | <input type="checkbox"/> | <input type="checkbox"/> | 10/12/14 1013 | W | 2 | | | | | | | |
| 1600-WC-H4112L | <input type="checkbox"/> | <input type="checkbox"/> | 1014 | W | | | | | | | | |
| 1600-WC-H4112E | <input type="checkbox"/> | <input type="checkbox"/> | 1014 | W | | | | | | | | |
| 1600-B51-H412 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1014 | W | | | | | | | | |
| 1600-WC-02-H4113L | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1015 | W | | | | | | | | |
| 1600-WC-02-H4113R | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1015 | W | | | | | | | | |
| 1600- W -02-104113 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1018 | W | | | | | | | | |
| 1600-S0-02-AWSR | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1018 | W | | | | | | | | |
| <u>FTS14</u> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1018 | W | | | | | | | | |
| 1600-B51-02-AWSR | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1021 | W | | | | | | | | |
| 1600-WC-03-104114L | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1021 | W | | | | | | | | |
| 1600-WC-03-104114R | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1024 | W | | | | | | | | |
| 1600-WC-03-104114 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1024 | W | | | | | | | | |
| 1600-WC-03-104114 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1025 | W | | | | | | | | |
| 1600-WC-03-104114 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1025 | W | | | | | | | | |
| 1600-WC-03-104114 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1025 | W | | | | | | | | |
| 1600-WC-03-104114 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1025 | W | | | | | | | | |
| 1600-WC-03-104114 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1027 | W | | | | | | | | |

(Lab) Received Temperature: _____ °C

Disregard
Per Email
10-27
Disregard
Per Email
10-27



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AC 39631

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

| Client Sample ID | Failure to complete will hinder processing of samples | | Collect Date/Time | Matrix W=Water S=Soil A=Air SL=Sludge O=Other | Preservative 1=HCL 2=HNO3 3=H2SO4 4=CE 5=Other | EPA 200. 8 | List Test(s) Needed | | | | Comments | |
|-------------------|---|-------------------------------------|-------------------|--|---|------------------|---------------------|--------------------|------------------|----------------------|----------|--|
| | Comp | Grab | | | | | Field pH | Field pH Test Time | Field Temp Deg C | Field Temp Test Time | | |
| 1600-BF-14115 | <input type="checkbox"/> | <input type="checkbox"/> | 10/2/24 1027 | W | 2 | | | | | | | |
| 1600-WC-02-14116L | <input type="checkbox"/> | <input type="checkbox"/> | 1024 | W | | | | | | | | |
| 1600-WC-02-14116R | <input type="checkbox"/> | <input type="checkbox"/> | 1029 | W | | | | | | | | |
| 1600-BF-02-14116 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1030 | W | | | | | | | | |
| 1600-WC-03-14117L | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1033 | W | | | | | | | | |
| 1600-WC-03-14117R | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1033 | W | | | | | | | | |
| 1600-BF-03-14117 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1023 | W | | | | | | | | |
| 1600-WC-02-14118L | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1035 | W | | | | | | | | |
| 1600-WC-02-14118R | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1035 | W | | | | | | | | |
| 1600-BF-02-14118 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1035 | W | | | | | | | | |
| 1600-SD-03-14119 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1037 | W | | | | | | | | |
| 2 Elksa | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1037 | W | | | | | | | | |
| 1600-FB | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 1038 | W | | | | | | | | |
| | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | W | | | | | | | | |
| | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | W | | | | | | | | |
| | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | W | | | | | | | | |
| | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | W | | | | | | | | |

(Lab) Received Temperature: _____ °C