

**Table 2 - Potable Water Testing**  
**Points of Use in Building**  
**KIPP Newark Lab High School**  
**18 Norfolk Street Newark, NJ**

Sample ID	Tectonic Field Number	Laboratory ID	Floor	Outlet Type	Sampling Date	Lead Result (µg/L)	NJDOE AL
Lab-FL1-R136B-IM	3	T5D0717-02	First	Ice Machine	04/25/25	<RL	15
Lab-FL1-RGYM-DF1	23	T5D0717-03	First	Drinking Fountain	04/25/25	<RL	15
Lab-FL1-RGYM-DF2	24	T5D0717-04	First	Drinking Fountain	04/25/25	<RL	15
Lab-FL1-RGYM-DFB	5	T5D0717-05	First	Drinking Fountain Bottle Filler	04/25/25	<RL	15
Lab-FL1-RKIT-KS1	6	T5D0717-06	First	Kitchen Sink	04/25/25	1.13	15
Lab-FL1-RKIT-SO	8	T5D0717-07	First	Sink Oven	04/25/25	7.18	15
Lab-FL1-RKIT-KS2	7	T5D0717-08	First	Kitchen Sink	04/25/25	<RL	15
Lab-FL1-RMO-WC	9	T5D0717-09	First	Water Cooler	04/25/25	<RL	15
Lab-FL1-R127-WC	2	T5D0717-10	First	Water Cooler	04/25/25	<RL	15
Lab-FL1-RGYM2-DF1	25	T5D0717-11	First	Drinking Fountain	04/25/25	<RL	15
Lab-FL1-RGYM2-DF2	26	T5D0717-12	First	Drinking Fountain	04/25/25	<RL	15
Lab-FL1-R115-WC	1	T5D0717-13	First	Water Cooler	04/25/25	<RL	15
Lab-FL2-R212-TS	11	T5D0717-14	Second	Teachers Sink	04/25/25	<RL	15
Lab-FL2-R212-WC	12	T5D0717-15	Second	Water Cooler	04/25/25	<RL	15
Lab-FL2-H210-DF	10	T5D0717-16	Second	Drinking Fountain	04/25/25	<RL	15
Lab-FL2-R224-WC	13	T5D0717-17	Second	Water Cooler	04/25/25	<RL	15
Lab-FL3-R312-WC	15	T5D0717-18	Third	Water Cooler	04/25/25	<RL	15
Lab-FL3-H310-DF	14	T5D0717-19	Third	Drinking Fountain	04/25/25	<RL	15
Lab-FL3-R319-TS	16	T5D0717-20	Third	Teachers Sink	04/25/25	2.28	15
Lab-FL3-R322-WC*	17	T5D0717-21	Third	Water Cooler	04/25/25	<RL	15
Lab-FL4-R410-WC	19	T5D0717-22	Fourth	Water Cooler	04/25/25	<RL	15
Lab-FL4-H405-DF	18	T5D0717-23	Fourth	Drinking Fountain	04/25/25	<RL	15
Lab-FL4-R417-TS	20	T5D0717-26	Fourth	Teachers Sink	04/25/25	7.01	15
Lab-FL4-R420-WC	22	T5D0717-24	Fourth	Water Cooler	04/25/25	<RL	15
Lab-FB	N/A	T5D0717-01	N/A	N/A	04/25/25	<RL	15
Lab-Dup	N/A	T5D0717-25	Fourth	Drinking Fountain	04/25/25	<RL	15

Sample concentrations in **negative (see to the right)** are exceeding the NJDOE criterion:

**>15.4**

\* Warm or hot water was sampled

**Qualifiers:**

<RL	Not detected above method detection limits / reporting limits
AL	New Jersey Department of Education (NJDOE) Action Level
µg/L	Micro-grams per Liter, Parts Per Billion or PPB
N/A	Not applicable